



Appendix H: Country Addendums

VERSION MARCH 2018

INDONESIA

Accepted Fuel Types: Geothermal (GE1)
Solar PV (SOL)
Wind (WND)

Requirements: Generating Unit must be interconnected to the local grid or the onsite energy user must be able to receive energy from the local grid.

Generation unit must have come online in the last 15 years, or be repowered, in order to be registered to issue TIGRs.

Generating Unit must have Revenue-Quality Meters, ANSI-C12 or other equivalent standard such as IEC Standards.

No sale, transfer or other use of TIGRs requiring registration or regulation by the applicable securities regulatory body is eligible.

If a local REC system or Renewable Portfolio Standard are developed, TIGRs will not be issued in respect to energy that is used for ether program.

TIGRs must be fully aggregated resources with all carbon benefit included, owned, and not sold separately or registered in another attribute tracking system including but not limited to the UNFCC's CDM registry.